

2017 Annual Drinking Water Quality Report

HANOVER
IL0850250

Annual Water Quality Report for the period of January 1 to December 31, 2017

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by HANOVER is Ground Water

For more information regarding this report contact:

Name: Gary Schoenfeld
Phone: 815-591-3800

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water
<p>The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.</p>
<p>Contaminants that may be present in source water include:</p> <ul style="list-style-type: none"> - Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. - Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. - Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. - Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.
<p>The Village of Hanover will not be mailing this year's Consumer Confidence Report (CCR), but will have it available upon request. The CCR includes basic information of the source(s) of your drinking water, the levels of any contaminants that were detected in the water during 2017, and compliance with other drinking water rules, as well as some educational materials. Copies of this year's report are available at Hanover Village Hall, 207 Jefferson Street, Hanover, IL (815-591-3800).</p>

<p>Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.</p>
<p>Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).</p>
<p>In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. If present, elevated levels of lead can cause serious health problems, especial for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. If you are concerned about lead you can flush your tap for 30 seconds to 2 minutes before using. If you are concerned about lead in your water and what you can do to have it checked, contact the SAFE DRINKING WATER HOTLINE AT [800-426-4791] or at http://www.epa.gov/safewater/lead.</p>

Source Water Information

Source Water Name	Type of Water	Report	Status	Location
WELL 1 (11743)	GW	Current		113 Monroe St.
WELL 2 (11744)	GW	Current		110 Fulton St.

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 815-591-3800. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Based on information obtained in a Well Site Survey published in 1989 by the Illinois EPA, several potential secondary sources are located within 1,000 feet of the wells. The Illinois EPA has determined that the Hanover Community Water Supply's source water is not susceptible to contamination. This determination is based on a number of criteria including; monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and available hydrogeologic data on the wells. Furthermore, in anticipation of the U.S. EPA's proposed Ground Water Rule, the Illinois EPA has determined that the Hanover Community Water Supply is not vulnerable to viral contamination. This determination is based upon the evaluation of the following criteria during the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper sitting conditions; a hydraulic barrier exists which should prevent pathogen movement; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate a viral contamination threat. Because the community's wells are constructed in a confined aquifer, which should prevent the movement of pathogens into the wells, well hydraulics were not considered to be a significant factor in the susceptibility determination. Hence, well hydraulics were not evaluated for this system ground water supply.

2017 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

---- If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.----

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	07/29/15	1.3	1.3	0.17	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	07/29/15	0	15	1.1	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits

Water Quality Test Results

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

N/A: not applicable.

Avg: Regulatory compliance with some MCLs is based on running annual average of monthly samples.

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	12/31/17	1.1	0.41 – 1.44	MRDLG=4	MRCL=4	ppm	N	Water additive used to control microbes.
Total Trihalomethanes (TThm)*	07/11/17	2.69	2.69 – 2.69	No goal for the total	80	ppb	N	By-product of drinking water chlorination.

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	04/12/17	0.11	0.087-0.11	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	04/12/17	0.96	0.894-0.958	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Iron	04/12/17	0.33	0.26-0.33	N/A	1.0	ppm	N	Erosion from naturally occurring deposits.
Manganese	04/12/17	3	2.8 – 3.0	150	150	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Nitrate {measured as Nitrogen}	04/12/17	0.02	0-0.02	10	10	Mg/l	N	Runoff from fertilizer use: Leaching from septic tanks, sewage:: Erosion of natural deposits.
Sodium	04/12/17	3.4	3.2-3.4	N/A	N/A	ppm	N	Erosion from naturally occurring deposits; Used in water softener regeneration.
Radioactive Contaminants	Collection Date	Highest Level	Range of Levels	MCLG	MCL	Units	Violation	Likely Source of Contamination

